








RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
District Water Testing Laboratory Vidyagiri 17th cross Near Hanuman Temple
Garden Backside Bagalkot-587102
E-mail: rdwsd.wqmspdistlabbagalkot@gmail.com

TEST REPORT					
B.N. Khot International Public School Anagawadi-587116 GP: Anagawadi Location: Inside school premise TQ: Bilagi Dist: Bagalkot			Report date:19-08-2022		
			Report Number:53		
			Reference: Sample receipt Form		
			Sample receipt date: 17-08-2022		
			Sample code: PVT22 AUG0053		
			Date of Sample collection: 17-08-2022		
			Temperature & Transport mode: 28C & Through Bag in Plastic Bottle		
			Analysis start date: 18-08-2022		
Analysis completion date: 18-08-2022					
Sample collection protocol: IS 3025(Part-1)					
Sample Particulars: Filter water		Sample Condition : Good		Sample quantity: 1L	
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Clear, Colourless, Odourless					
1.	pH Value @Temp 25°C	7.58	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance,µS/cm@Temp 25°C	215	—	—	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-7 & 8):1983
5.	Colour, Hazen Units	<5	5	15	IS 3025 (Part-4) :2021
6.	Turbidity, NTU	0	1	5	IS 3025 (Part-10) : 1984
7.	Total Dissolved Solids@ 180°C,mg/l	152	500	2000	IS 3025 (Part-16) : 1984
8.	Alkalinity as CaCO ₃ , mg/l	66	200	600	IS 3025 (Part-23) : 1986
9.	Total Hardness as CaCO ₃ , mg/l	86.32	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	15.69	75	200	IS 3025 (Part-40) : 1991
11.	Magnesium as Mg, mg/l	11.44	30	100	IS 3025 (Part-46) : 1994
12.	Chloride as Cl, mg/l	41.39	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO ₄ , mg/l	9.21	200	400	IS 3025 (Part-24) : 2022
14.	Fluoride as F, mg/l	0.21	1	1.5	APHA 23 rd Edition
15.	Nitrate as NO ₃ , mg/l	5.54	45	No relaxation	APHA 23 rd Edition
16.	Iron as Fe, mg/l	0.06	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The given Sample confirms to the Acceptable Limit of IS 10500 : 2012 RA:2018 Drinking water specification for the above Chemical & Physical parameters tested only. (Sample brought by customer)					
 Analysed by Senior Analyst: Mrutyunjay		 Checked by Quality Manager: Ashwini Date: 19-08-2022		 Authorized Signatory Executive Engineer:V.A.Rathod Date: 19-08-2022	


PRINCIPAL,
B.N. Khot International
Public School,
ANAGAWADI-587 116.
Tq: Bilagi) (Dist: Bagalkot.(Karnataka)
Affiliation No.-831026


President,
Shri Banashankari Devi Vidya Sansthe
ANAGAWADI

PROFORMA REGARDING HEALTH AND SANITARY CONDITION CERTIFICATE

No. 19/2021-2022

Date: 20-01-2022

It is certified that an inspection team headed by Dr. Anilkumar Badnur (Name of the Officers with designation) from **Primary Health Care Centre, Kundargi Tq: Bilagi Dist: Bagalkot, St: Karnataka** (Name of Department/Office) inspected the **B.N.KHOT INTERNATIONAL PUBLIC SCHOOL, Anagawadi Tq: Bilagi Dist: Bagalkot, St: Karnataka** (Name & Address of the School) on 20-01-2022 and found that the **B.N.KHOT INTERNATIONAL PUBLIC SCHOOL, Anagawadi** (Name of the school) has **MAINTAINING GOOD HEALTH AND SANITARY CONDITION** facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building the campus as per the norms prescribed by the Central/State/U.T.Govt.

The above is valid for a period of 1 year

Signature with seal : 

Name :

Designation :

20/1/2022
Administrative Medical Officer
Primary Health Centre, KUNDARGI.
Tq: Bilagi, Dist: Bagalkot.

To,


B.N.KHOT INTERNATIONAL PUBLIC SCHOOL

N.H.218, Vijayapur-Hubli Highway,

Near Indian oil Petrol Pump

Anagawadi Tq: Bilagi Dist: Bagalkot, St: Karnataka

(Name & Address of the Institution)



PRINCIPAL,
B.N. Khot International
Public School,
ANAGAWADI-587 116.

Tq: Bilagi (Dist: Bagalkot.(Karnataka)
Attnation No.-831026



President,
Shri Banashankari Devi Vidya Sansthe
ANAGAWADI